SUBMITTAL

Part Number:

Strap-on Temperature Transmitter PRODUCT SELECTION INFORMATION:

MODEL	Product Description
	Strap-on Temperature Transmitter c/w LCD display °C Strap-on Temperature Transmitter c/w LCD display °F

CODE	Enclosure (ABS enclosure is standard)	
-	ABS enclosure, standard (no code required, leave blank)	
W	PVC weatherproof box	

CODE	Secondary Sensor (Leave blank if not required)		
2	PT100-100 Ω Plat. IEC 751, 385 Alpha, thin film		
5	1801 Ω , NTC Thermistor, ±0.2°C		
6	3000 Ω , NTC Thermistor, ±0.2°C		
7	10,000 Ω , Type 3, NTC Thermistor, ±0.2°C		
8	2.252 KΩ , NTC Thermistor, ±0.2°C		
9	100,000 Ω , NTC Thermistor, ± 0.2 °C		
12	PT1000-1000 Ω Platinum, IEC 751, 385 Alpha, thin film		
13	1000 Ω Nickel		
14	10,000 Ω , Type 3, NTC Thermistor, $\pm 0.2^{\circ}$ C c/w 11K shunt resistor		
15	PT3000 PTC Platinum, ±0.2°C		
20	$20,000\Omega$, NTC Thermistor, $\pm 0.2^{\circ}\mathrm{C}$		
24	10,000 Ω, Type 2, NTC Thermistor, ±0.2°C		

CODE	Probe Length
_	
Α	50 mm (2")
В	100 mm (4")
С	150 mm (6")
D	200 mm (8")
E	300 mm (12")
F	450 mm (18")

Probe Material

CODE

2	304 Stainle	less steel	
	CODE	Transmitter Output Signal	
	A D E	Current 4-20mA Voltage 0-5 Vdc Voltage 0-10 Vdc	
		CODE	Transmitter Range
		1 2	0 - 35°C (32 - 95°F) 0 - 50°C (32 - 122°F)
		3	0 - 100°C (32 - 212°F)
		*	Custom range, please contact Greystone

TE511E - - A 2 1A 2

Greystone Energy Systems, Inc. reserves the right to make design modifications without prior notice.

EXAMPLE: Strap-on c/w °C LCD, 2" S/S, 4-20mA. 0-50°C

*Custom Range:



GREYSTONE

ACCURACY BY DESIGN

Greystone Energy Systems, Inc. 150 English Drive, Moncton, NB Canada E1E 4G7

(506) 853-3057 Fax: (506) 853-6014 North America: 1-800-561-5611 e-mail: mail@greystoneenergy.com www.greystoneenergy.com The TE511/512E single point strap-on temperature transmitter incorporates a precision platinum RTD encapsulated in a 6.35 mm (0.25") OD, 304 stainless steel probe and is available in various lengths (see ordering chart). All probes provide excellent heat transfer, fast response and resist moisture penetration. A transmitter that provides a high accuracy signal with excellent long term stability, low hysteresis and fast response for measurement of pipe temperatures. A LCD is provided in either °C (511) or °F (512). A secondary sensor option is available.

Sensor Operating Temperature Range	-20 to 105 °C (-4 to 221 °F) Higher ranges available, please contact Greystone		
Enclosure	Standard - ABS - UL94-V - NEMA 1 (IP23) Weatherproof (W) - PVC - NEMA 4X (IP66)		
Cable	PVC insulated, parallel bonded (100 ohm - Type 2 uses FT-4)		
Probe	304 Series stainless steel with spin welded tip		
Output Signal	Current: 4-20 mA current loop Voltage: 0-5 or 0-10 Vdc (Factory Configured)		
Transmitter Accuracy	±0.1% of span, including linearity		
Power Supply	Current: 15-35 Vdc or 22-32 Vac Voltage: 0- 5 Vdc: 10-35 Vdc or 10-32 Vac 0-10 Vdc: 15-35 Vdc or 15-32 Vac		
Power Consumption	Current: 22.5 mA Max. (Occurs with open sensor) Voltage: 5 mA nominal		
PCB Operating Temperature	0° to 70°C (32° to 158°F)		
Wiring Connections	Two or three wires Screw terminal block (14 to 22 AWG)		
Display Units	°C (511) or °F (512) - Factory set		
Display Range	0° to 100°C typical range for transmitter		
Display Resolution	0.1°C or 0.1°F for display of 00.0 to 99.9		
Display Accuracy	±0.2°C or ±0.2°F over full range		
Display Accuracy Display Update Rate	±0.2°C or ±0.2°F over full range 3 times per second		

Installation:

For complete installation and wiring details, please refer to the product installation instructions.

For best results, thermal conductive compound should be applied to pipe prior to mounting the probe.

Find a suitable location along the pipe where both the probe and remote enclosure can be mounted. If necessary, remove a section of insulation from pipe. Position probe directly on the pipe and secure using a pipe clamp. For added security, make 1-3 loops of the sensor cable around the pipe and feed through wire hole on the enclosure and secure using the supplied grommet. If necessary, the pipe insulation can be re-applied to the pipe over the probe.











Typical Installation:



Dimensions:



ABS Enclosure

